

Monk Lake 2

RESERVOIRS ACT 1975 (as amended)

Direction under Section 12AA(4), by the appointed engineer as to the testing of a flood plan.

I, Geoffrey Wilson of 3 The Osier Field Ball Lane Kennington Ashford Kent TN25 4PL being a member of the Non-Impounding Reservoirs Panel of Engineers, appointed by Taytime Limited to consult on the flood plan under section 12A for the reservoir known as Monk Lake 2 situated at OS grid ref. TQ768476 direct that the flood plan be tested as specified below, the interval commencing on 22 April 2023. A report of the test shall be provided to assess the need for revision of the plan.

Element of flood plan	Manner of testing	Interval between tests
On-site flood plan	Desk based study, run through and site walk-over	Annual
Off-site flood plan	Full incident simulation, Liaise with Police and Local Resilience Forum	10 years

Signature of Engineer:



Member of the Non-Impounding Reservoirs Panel of England and Wales
(Current appointment expires 23 August 2023)

Date of certificate: 15 May 2022